

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Electric Power Cable

with type designation(s)
MOR Polyrad XT-125, Type P, SP 1 kV, MOR Polyrad XT-125, Type P, SP(HD) 2 kV

Issued to
General Cable
WILLIMANTIC CT, United States

is found to comply with
Det Norske Veritas' Rules for Classification of Ships, High Speed & Light Craft and Det Norske Veritas' Offshore Standards
IEEE 1580 (2010)
IEEE 45 1998
IEC 60332-3-22 (2009-02)

Application :

General power and lighting, control.
Mud resistant according to NEK606.

Type	Voltage class (kV)	Temp. class (°C)
MOR Polyrad XT-125, Type P, SP 1 kV	1	95
MOR Polyrad XT-125, Type P, SP(HD) 2 kV	2	95

This Certificate is valid until **2015-06-30**.

Issued at **Høvik** on **2014-08-26**

for **DNV GL**

DNV GL local station: **New York**

Approval Engineer: **Ivar Bull**

.....
Marit Laumann
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed. If any person suffers loss or damage which is proven to have been caused by any negligent act or omission of the Society, then the Society shall pay compensation to such person for his proven direct loss or damage. However, the compensation shall not exceed an amount equal to ten times the fee charged for the service in question. The maximum compensation shall never exceed USD 2 million. In this provision the "Society" shall mean DNV GL AS as well as all its direct and indirect owners, affiliates, subsidiaries, directors, officers, employees, agents and any other person or entity acting on behalf of DNV GL AS.

Certificate No: **E-11175**
 File No: **827.10**
 Job Id: **262.1-004504-3**

Product description

Type: MOR POLYRAD XT-125, Type P, SP 1 kV
 MOR POLYRAD XT-125, Type P, SP(HD) 2 kV

Conductor:	Tinned stranded copper
Insulation:	XLPO(Cross-linked Polyethylene) (Type P)

Number of cores x conductor cross- section		Overall diameter	
mm ²	AWG/MCM	mm	inches
1 x 0,96	18	2,82	0,111
1 x 1,22	16	3,10	0,122
1 x 1,94	14	3,51	0,138
1 x 3,08	12	3,94	0,155
1 x 5,52	10	4,70	0,185
1 x 7,57	8	6,02	0,237
1 x 12,48	6	6,91	0,272
1 x 18,52	5	8,89	0,350

Number of cores x conductor cross- section		Overall diameter	
mm ²	AWG/MCM	mm	inches
1 x 21,49	4	9,40	0,370
1 x 25,58	3	9,27	0,365
1 x 30,70	2	10,92	0,430
1 x 46,05	1	13,03	0,513
1 x 56,29	1/0	14,27	0,562
1 x 66,53	2/0	15,24	0,600
1 x 92,11	3/0	17,45	0,687

SP2KV(HD)

Number of cores x conductor cross- section		Overall diameter	
mm ²	AWG/MC M	mm	inches
1 x 7,57	8	6,53	0,257
1 x 12,48	6	7,04	0,277
1 x 18,52	5	9,02	0,355
1 x 21,49	4	9,52	0,375
1 x 25,58	3	10,16	0,400
1 x 30,70	2	11,05	0,435
1 x 46,05	1	13,16	0,518
1 x 56,29	1/0	14,40	0,567
1 x 66,53	2/0	15,37	0,605
1 x 92,11	3/0	17,58	0,692

Number of cores x conductor cross- section		Overall diameter	
mm ²	AWG/MC M	mm	inches
1 x 112,59	4/0	20,95	0,825
1 x 133,06	262	22,10	0,870
1 x 158,65	313	23,88	0,940
1 x 189,35	373	25,53	1,005
1 x 224,97	444	27,56	1,085
1 x 271,24	535	30,10	1,185
1 x 327,53	646	32,89	1,295
1 x 394,06	777	35,31	1,390
1 x 562,44	1111	40,89	1,610

Application/Limitation

The requirements of SOLAS Amendments 1981 Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Tests carried out


Type tests according to IEEE 45, IEC 60092-350 and IEC 60332-3 cat. A

Marking of product

MOR POLYRAD XT-125, Type P, SP 1 kV - - IEC 60332-3-22 - Lot No or
 MOR POLYRAD XT-125, Type P, SP(HD) 2 kV - IEC 60332-3-22 - Lot No

Periodical assessment

The scope of the Periodical assessment is to verify that the conditions stipulated for the Type approval is complied with and that no alterations are made to the product design or choice of materials.



Certificate No: **E-11175**
File No: **827.10**
Job Id: **262.1-004504-3**

The main elements of the survey are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Production Sample Tests (PST) and Routines (RT) checked (if not available tests according to PST and RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Survey to be performed at least every second year.

END OF CERTIFICATE